



**Jim Doyle, Governor**  
**Jack L. Fischer, A.I.A., Secretary**

July 11, 2008

T.R. ARNOLD & ASSOC  
WILLIAM B RHODES  
700 E BEARDSLEY AV  
ELKHART IN 46515

FOUR SEASONS HOUSING/  
ADMIRATION BUILDERS  
PAT HOLSTETLER  
11333 CR 2  
MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: FOUR SEASONS HOUSING/  
Product Name: MODULAR HOUSING PLUMBING SYSTEM, 3-BED, 2 1/2 BATH  
Model Number(s): ABM 10259  
9232-1 FLOOR PLAN 1&2  
Product File No: 20080083

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 31 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The installation of air admittance valves must comply with the Wisconsin Department of Commerce plumbing product approval for the particular valve being installed.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: Jerry.Thompson@wi.gov